CIVIL PRO

AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005

4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE KERB STONE

Lab ID	:	**CP-2018-01-12-06** **Date: 16-01-18**
Customer	:	Assistant Executive Engineer, T.Dasarahalli Sub Division, BBMP, Bangalore.
Address	:	T.Dasarahalli Sub Division, BBMP, Bangalore.
Project Name	:	Construction of RCC drain & Improvements to cross roads, 1st, 2nd, 3rd, 4th, 5th,& Culvert at Grape Garden T.Dasarahalli Ward No.15
Agency	:	Technical Manger(West), KRIDL, Project Implementation Unit, No.280, 59th Cross, 17th 'C' Main Road, 3rd 'Y' Block, Rajajinagar, Bangalore-560 010
Customer's Reference	:	BBMP/EE/DD/WO/184/2017-18
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	12-01-18
Sample ID No	:	2018-01-12-06/03
Sample Type /Size	:	CC Kerb Stone/ 450*165*400mm
Reference to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete
Date of test	:	12/01/2018

Sl. No.	Identification Mark	Diameter of the core	Height of the core	Weight of	Area	Failure	Core	Corrected	Equivalent

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No.: TC-5548

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID	:	**CP-2018-01-22-04** **Date: 25/01/2018**
Customer	:	Assistant Executive Engineer, T.Dasarahalli Sub Division, BBMP, Bangalore.
Address	:	T.Dasarahalli Sub Division, BBMP, Bangalore.
Project Name	:	Construction of RCC drain & Improvements to cross roads, 1st, 2nd, 3rd, 4th, 5th,& Culvert at Grape Garden T.Dasarahalli Ward No.15
Agency	:	Technical Manger(West), KRIDL, Project Implementation Unit, No.280, 59th Cross, 17th 'C' Main Road, 3rd 'Y' Block, Rajajinagar, Bangalore-560 010
Customer's Reference	:	BBMP/EE/DD/WO/184/2017-18
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	22-01-18
Sample ID No	:	2018-01-22-04/01
Customer ID	:	M20 Concrete
Sample Type /Size	:	150X150X150 mm
Sample grade/Age	:	M20 / 7 Days Compressive Strength
Reference to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test	:	25/01/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen	Cross sectional area	Weight of the sample	Failure Load	Compressive strength	Average Compressive Strength

CIVIL PRO

AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005

4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID	:	**CP-2018-01-22-04** **Date: 15/02/2018**
Customer	:	Assistant Executive Engineer, T.Dasarahalli Sub Division, BBMP, Bangalore.
Address	:	T.Dasarahalli Sub Division, BBMP, Bangalore.
Project Name	:	Construction of RCC drain & Improvements to cross roads, 1st, 2nd, 3rd, 4th, 5th,& Culvert at Grape Garden T.Dasarahalli Ward No.15
Agency	:	Technical Manger(West), KRIDL, Project Implementation Unit, No.280, 59th Cross, 17th 'C' Main Road, 3rd 'Y' Block, Rajajinagar, Bangalore-560 010
Customer's Reference	:	BBMP/EE/DD/WO/184/2017-18
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	22-01-18
Sample ID No	:	2018-01-22-04/02
Customer ID	:	M20 Concrete
Sample Type /Size	:	150X150X150 mm
Sample grade/Age	:	M20 / 28 Days Compressive Strength
Reference to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test	:	15/02/2018

Sl. No.	Identification Mark	Grade of	Date of Casting	Date of Testing	Dimension of the	Cross sectional	Weight of the	Failure Load	Compressive strength	Average Compressive

CIVIL PRO

AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005

4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID	:	**CP-2018-01-22-04** **Date: 25/01/2018**
Customer	:	Assistant Executive Engineer, T.Dasarahalli Sub Division, BBMP, Bangalore.
Address	:	T.Dasarahalli Sub Division, BBMP, Bangalore.
Project Name	:	Construction of RCC drain & Improvements to cross roads, 1st, 2nd, 3rd, 4th, 5th,& Culvert at Grape Garden T.Dasarahalli Ward No.15
Agency	:	Technical Manger(West), KRIDL, Project Implementation Unit, No.280, 59th Cross, 17th 'C' Main Road, 3rd 'Y' Block, Rajajinagar, Bangalore-560 010
Customer's Reference	:	BBMP/EE/DD/WO/184/2017-18
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	22-01-18
Sample ID No	:	2018-01-22-04/03
Customer ID	:	M20 Concrete
Sample Type /Size	:	150X150X150 mm
Sample grade/Age	:	M20 / 7 Days Compressive Strength
Reference to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test	:	25/01/2018

Sl. No.	Identification Mark	Grade of	Date of Casting	Date of Testing	Dimension of the	Cross sectional	Weight of the	Failure Load	Compressive strength	Average

CIVIL PRO

AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005

4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2018-01-22-04** **Date: 15/02/2018**

Customer : Assistant Executive Engineer, T.Dasarahalli Sub Division, BBMP, Bangalore.

Address : T.Dasarahalli Sub Division, BBMP, Bangalore.

Project Name : Construction of RCC drain & Improvements to cross roads, 1st, 2nd, 3rd, 4th, 5th,& Culvert at Grape Garden T.Dasarahalli Ward No.15

Agency : Technical Manger(West), KRIDL, Project Implementation Unit, No.280, 59th Cross, 17th 'C' Main Road, 3rd 'Y' Block, Rajajinagar, Bangalore-560 010

Customer's Reference : BBMP/EE/DD/WO/184/2017-18

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 22-01-18

Sample ID No : 2018-01-22-04/04

Customer ID : M20 Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 15/02/2018

Sl. No.	Identification Mark	Grade of	Date of Casting	Date of Testing	Dimension of the	Cross sectional	Weight of the	Failure Load	Compressive strength	Average Compressive

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No.: TC-5548

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID	:	**CP-2018-01-22-04** **Date: 25/01/2018**
Customer	:	Assistant Executive Engineer, T.Dasarahalli Sub Division, BBMP, Bangalore.
Address	:	T.Dasarahalli Sub Division, BBMP, Bangalore.
Project Name	:	Construction of RCC drain & Improvements to cross roads, 1st, 2nd, 3rd, 4th, 5th,& Culvert at Grape Garden T.Dasarahalli Ward No.15
Agency	:	Technical Manger(West), KRIDL, Project Implementation Unit, No.280, 59th Cross, 17th 'C' Main Road, 3rd 'Y' Block, Rajajinagar, Bangalore-560 010
Customer's Reference	:	BBMP/EE/DD/WO/184/2017-18
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	22-01-18
Sample ID No	:	2018-01-22-04/07
Customer ID	:	M20 Concrete
Sample Type /Size	:	150X150X150 mm
Sample grade/Age	:	M20 / 7 Days Compressive Strength
Reference to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test	:	25/01/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen	Cross sectional	Weight of the	Failure Load	Compressive strength	Average Compressive

CIVIL PRO

AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005

4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID	:	**CP-2018-01-22-04** **Date: 15/02/2018**
Customer	:	Assistant Executive Engineer, T.Dasarahalli Sub Division, BBMP, Bangalore.
Address	:	T.Dasarahalli Sub Division, BBMP, Bangalore.
Project Name	:	Construction of RCC drain & Improvements to cross roads, 1st, 2nd, 3rd, 4th, 5th,& Culvert at Grape Garden T.Dasarahalli Ward No.15
Agency	:	Technical Manger(West), KRIDL, Project Implementation Unit, No.280, 59th Cross, 17th 'C' Main Road, 3rd 'Y' Block, Rajajinagar, Bangalore-560 010
Customer's Reference	:	BBMP/EE/DD/WO/184/2017-18
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	22-01-18
Sample ID No	:	2018-01-22-04/08
Customer ID	:	M20 Concrete
Sample Type /Size	:	150X150X150 mm
Sample grade/Age	:	M20 / 28 Days Compressive Strength
Reference to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test	:	15/02/2018

Sl. No.	Identification Mark	Grade of	Date of Casting	Date of Testing	Dimension of the	Cross sectional	Weight of the	Failure Load	Compressive strength	Average Compressive

CIVIL PRO

AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005

4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID	:	**CP-2018-01-22-04** **Date: 25/01/2018**
Customer	:	Assistant Executive Engineer, T.Dasarahalli Sub Division, BBMP, Bangalore.
Address	:	T.Dasarahalli Sub Division, BBMP, Bangalore.
Project Name	:	Construction of RCC drain & Improvements to cross roads, 1st, 2nd, 3rd, 4th, 5th,& Culvert at Grape Garden T.Dasarahalli Ward No.15
Agency	:	Technical Manger(West), KRIDL, Project Implementation Unit, No.280, 59th Cross, 17th 'C' Main Road, 3rd 'Y' Block, Rajajinagar, Bangalore-560 010
Customer's Reference	:	BBMP/EE/DD/WO/184/2017-18
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	22-01-18
Sample ID No	:	2018-01-22-04/05
Customer ID	:	M20 Concrete
Sample Type /Size	:	150X150X150 mm
Sample grade/Age	:	M20 / 7 Days Compressive Strength
Reference to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test	:	25/01/2018

Sl. No	Identification Mark	Grade of	Date of Casting	Date of Testing	Dimension	Cross	Weight of	Failure	Compressive	Average

CIVIL PRO

AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005

4, 7TH MAIN MALLESWARAM, BANGALORE -3

Certificate No.: TC-5548

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2018-01-22-04** **Date: 15/02/2018**

Customer : Assistant Executive Engineer, T.Dasarahalli Sub Division, BBMP, Bangalore.

Address : T.Dasarahalli Sub Division, BBMP, Bangalore.

Project Name : Construction of RCC drain & Improvements to cross roads, 1st, 2nd, 3rd, 4th, 5th,& Culvert at Grape Garden T.Dasarahalli Ward No.15

Agency : Technical Manger(West), KRIDL, Project Implementation Unit, No.280, 59th Cross, 17th 'C' Main Road, 3rd 'Y' Block, Rajajinagar, Bangalore-560 010

Customer's Reference : BBMP/EE/DD/WO/184/2017-18

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 22-01-18

Sample ID No : 2018-01-22-04/06

Customer ID : M20 Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 15/02/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen	Cross sectional area	Weight of the sample	Failure Load	Compressive strength	Average Compressive Strength